D- 41751 Viersen-Dülken · Textilstr.2 ☎ +49 (0) 2162-5030621 🖂 +49 (0) 2162-5030629

DC/DC – Converters

Characteristics:

- Supply voltage 24VDC
- Output 5VDC/1A
- Status display in front panel
- Mountable on 35mm cap rail TS35
- Clear terminal labeling
- Narrow design
- Shape 22,5mm, super low
- High reliability, 5 years warranty



DC1



Description:

The units of the DC/DC converters series DC1 have been developed for supplying small electrical consumers. They are controlled converters and therefore very low loss. One LED in output displays the ON-position.

Application:

Decentralized 5VDC supply

Order-No.:


Output:


DC1-2 5VDC / 1A





DC1-2





LEG www.LEG-GmbH.de info@LEG-GmbH.de

Technical Data

Auxiliary power:	
Supply voltage :	1933VDC 1822VAC
Peak voltage :	35V
Efficiency :	>75%
Outputs:	
	DC1-2
Output voltage :	5VDC ±2%
Output current :	1A
Temperature coefficient:	0, 05% / K
Voltage change	
Load 0100% :	±0, 05%
Load correction :	±1, 5%
Harmonic :	<50mV
General data:	
Operating temperature :	050°C
Storage temperature :	-25+85°C, condensation before putting into operation is not allowed
Insulation voltage :	1kVDC
CE conformity :	EN 61326-1, EN 61000-4-2/3*/4/5/6*, EN 61000-6-4 * during measurements are small deviations possible
	during measurements are small deviations possible
Body:	
Dimension :	See drawing, 22,5mm adjoin body, 22,5x70,4x90,5mm (with terminals)
Material :	PA / V0
Protection category :	IP20
Connection :	M3-screw-type terminal 0, 14 – 2,5mm ² , flexible or inflexible
Fixing :	Snap-on mounting for norm rail TS35
Weight :	80g

Data sheet DC1 revision: 04 - 2015

D- 41751 Viersen-Dülken · Textilstr.2 ☎ +49 (0) 2162-5030621 🖂 +49 (0) 2162-5030629

LEG www.LEG-GmbH.de info@LEG-GmbH.de

Note on safety:

Disconnect the power supply before attempting to open the unit.

During the operation of this module it is possible that parts of the module, even there is extra-low voltage, (for example shunt measurement) are under dangerous voltage! Therefore a non-observance of this caution may cause damage of property or physical injury.

Only trained qualified personnel should install or operate the unit. Before installation the qualified personnel should read the documentation and should familiarize themselves with the unit.

If there is visible damage to the body of the unit it should be immediately replaced and not put into operation.

Please ensure that there is a sufficient prevention against electrostatic discharge during installation of the unit.

Installation Information:

Pay attention and make sure the unit is far away from mounted sources that may disturb the device such as magnetic coils, transformers, frequency converters etc.

Wiring advise:

Use only shielded cables. The shield is to be connected extensively to ground. Do not mix power- and signal-wires/cables in the same cable tray.

Limited guarantee:

The LEG Industrie-Elektronik GmbH warranted that the product does not have any material or processing defects in a period of 5 years after date of delivery.

It is up to the choice of LEG to repair or to exchange an inoperative unit.

Subsequent damages or any claim for indemnification above the functionality of the unit are excluded. This limited warranty is only valid if ...

- 1. the product was installed and put into operation according to the LEG operation documentation;
- 2. the technical configuration of the power supply was abided;
- 3. the product was not used for unintended purposes;
- 4. there were no unauthorized modifications or manipulations, misuse or repairs without previous agreement from LEG.

Our Terms of Trade are based on the "General Conditions for the supply of products and services of the Electrical and Electronics Industry" including the "Complementary Clause: Extended Reservation of Property" of the <u>ZVEI</u> e.V. (German Association of Electrical Manufacturers).

Miscellaneous:

We expressly reserve the right, without previous notice, to correct errors contained in any data of this information brochure, and to make alterations to the program and technical modifications.

